



A CONCISE REVIEW ON OPTIMIZATION POTENTIALS ON WORKING FLUIDS USED IN POWER CYCLES

JYOTI SINGH¹, Dr. MAYANK MAHESHWARI², Dr. APURVA ANAND³

RESEARCH SCHOLAR BABU BANARSI DAS UNIVERSITY, ALLEN HOUSE INSTITUTE OF TECHNOLOGY
KANPUR, PROFESSOR MAHARANA PRATAP INSTITUTE OF TECHNOLOGY KANPUR

Abstract:

In industrial field, the gas turbines has been extensively used in combined power plant cycles that depicts low efficiency. These power plants are developed of steam and gas turbines. The gas turbine power plants are lighter and smaller than the steam power plants where the cost of every unit is less and the time required for delivering the gas turbine is comparatively shorter. This review discuss on various refrigerant fluids for increasing the efficiency or output of the power plants associated with trans-critical carbon di oxide, gas turbine and ammonia water solution. Energy conservation is prominent globally irrespective of non-renewable or renewable types. The refrigerants needs to be optimized in ventilation, heating, air conditioning to overcome several hazardous effects due to ozone depletion impact and greenhouse effect. Among those the carbon di oxide refrigeration cycle are primary and hence crucial importance has to be provided to this scenario. This review also discussed the various modified technologies with prominent performance and features. Accordingly potential future developments are also summarized in this review.

Key words: ORC(Organic rankine cycle), TRC(Transcritical rankine cycle), WHR(Waste heat recovery, LNG (Liquefied natural gas), CO₂-based Transcritical Power Cycle (CTPC), (carbondioxide transcritical power cycle) CDTPC, TIT(Turbine inlet temperature), ultra-supercritical(USC), combined power and cooling(CPC), Absorption cooling system(ACS), combined cycle gas turbine (CCGT), Inlet guide vane(IGV)

1. Introduction

The carbon di oxide refrigeration systems are rescued from earlier theory as the technical and reasonable solution for replacing the artificial refrigerants in the refrigeration application and air conditioning. Scientific community needs more effort to focus on the alternative refrigeration schemes and improving the performance of the individual operations.

The steam turbine is a heat engine that transforms heat energy into mechanical energy. The combustor, compressor and turbine forms the three basic forms of simple gas turbine. With reference to the Brayton cycle, it is understood that the operation of the gas turbine, compressed air and fuel are integrated and burnt at a constant pressure. For power generation, the expansion of the hot air is performed through turbine. The effectiveness of the turbine is also improves with steam turbine generator. Chemical looping combustion system is combusted using the metal oxide instead of oxygen in the air. The optimization of the turbine water rate leads to the considerable reduction in the consumption of the energy. In general, back pressure, steam consumption and condensation are influenced by various operations. Synthetic refrigerants replaces carbon di oxide after 1930s due to its adorable, safe and environmentally sustainable characteristics.

When compared with other organic fluids, carbon di oxide is found to be economic, ecofriendly and safe. Various industrial applications takes advantage from sub-freezing refrigeration supplied by ammonia based units with comparatively low temperature. All the cycles has to be optimized to obtain overall effectiveness. Hence there is a possibility to develop combined cycle configurations with varied gas turbine, ammonia-water turbine arrangements and steam turbine to compare the performance through thermodynamic modelling of the basic elements in combined cycle configurations.

2. Effect of Topping cycle parameters:

In a topping cycle, the fuel supplied is used to first produce power and then thermal energy, which is the by-product of the cycle and is used to satisfy process heat or other thermal requirements. Topping cycle cogeneration is widely used and is the most popular method of cogeneration.

3. Effect of Pressure And Temperature on cycle:

An efficient gas turbine retrofit is inter-stage turbine reheat. Reheat enhances net work output and cools the HRSG in SI periods, but it also has higher fuel consumption and may result in a reduction in thermal efficiency. This work [1] has been found to significantly improve cycle network, but that is not accurate for periods with modest stress variation if maximum thermal efficiency is the primary requirement. Findings illustrate that a nice deal among the highest possible network & the highest caloric performance are seen when the warm-up temperature equates to 0.4th powers to the peak cycle stress. In such a case, reheating given a 35.5% increase in net cycle work at a mere 5% efficiency cost. Similarly an exergoeconomic technique is used to analyse how major characteristics of the suggested cycle behave in relation to cycle operational parameters (turbine inlet temperature and compression pressure ratio) [2].

A study of combined cycle [3] topologies with intercooling and reheating that feature a gas turbine, a steam turbine, and an ammonia-water generator. The cost of producing power is 0.06727 USD/kWh, which is the minimal cost for producing the most amount of work. Likewise the research findings described that the improved waste heat recovery system was impacted by Gas re-circulation rate, boiler load and output temperature in preheater [4, 5]. Usually, it is suggested by [6] to use the deaerator option that draws steam from a secondary pressure turbine. The double-reheat cycle achieved a 1.22% relative improvement in net efficiency over the single-reheat standard cycle for the same identical expenditures. [7] presents the redesigned cycle's short-term operational flexibility, It demonstrates that as compared to the traditional Rankin cycle (CRC), The maximum power output augmentation drops by 6.0-28.1 MW, while the total power generation's adjusting time increases by 492.9-550.6 s. To improve response effectiveness and lower deaerator (DTR) pressure, control techniques are recommended and evaluated. The results indicate that the maximum negative overshoot value and adjusting time of the total power may be decreased. For the four working fluids under consideration, CO₂ has the highest ideal value for the thermal and w-net turbine inlet pressure, followed by SF₆, R32, and R125, in that order [8]. The research [9] demonstrates that the addition of a carbon capture module boosts the combined system's overall work output from 220.9 MW to 370 MW at cycle pressure ratio of 20. [10] presents for superlative a high effectively, recovered gas engine periods with less temperature rising, as bottom cycle plant. Reheating is a retrofit that increases power recovery by raising the specific network output of the base cycle. When the Rolls-Royce WR-21 and SM-50 are used together, benzene may provide more power, up to 1292.033 kW and 4772.631 kW for a situation in which reheating occurs at a temperature of 557.15K, accordingly. With higher reheating temperatures, the potential for power recovery increases. Reheating results in an improvement in energy efficiency.

Presents designing an original merged cooler and temperature system of power that reliably and efficiently recovers waste heat using the next-generation sCO₂ duration in addition to other possible mixtures. The investigation shows that, with the exception of a change in the temperature on the hot side of the generator, all parameters rise, increasing net work done. The pressure ratio of the RBC, the pressure at the GT inlet, the isentropic efficiency of the GT, and lastly the variance in temperature on the hot side of the absorption freezing cycle generator all have an impact on the overall system's co-efficient of performance (COP) and energy utilisation factor (EUF). A maximum value of 49.09% and a COP of 0.72 are attained by the EUF. [11, 12] presents the outputs of GT, ST, ORC and ACS, each of which uses the exhaust heat from a gas turbine plant above it to generate additional power and cooling, are compared. In order to compare the CPC systems, power- and vitality-supported parametric evaluations are performed, illustrating the execution changes with HRSG vapor pressure ranging from 89-94 bar. GT plant alone was determined to contribute more than 95% of the irreversibility in all four systems [13].

[14]Maheshwari et.al. Presents eight brand-new intercooled gas turbine-based combined cycles with closed loop cooling for the gas turbine blades. The ambient temperature is 303 K and the turbine's inlet temperature is 2000 K. The results show that an ammonia distillation of 0.6 produces the most work, 1142 kJ/kg, while an ammonia distillation of 0.7 at a cycle force proportion of 40 produces the most cycle proficiency, 53.87%, and second law efficiency, 58.46%, for a mixed cycle with a triple stress heat restoration vapour generator that uses the Rankin cycle at low pressure and an ammonia-water cycle at high and intermediate pressures.[14].[15]Abudu et.al. Presents while the stand-alone gas turbine saw a 34% improvement, the CCGT's extended MEL represents a 19% improvement. The advantages of flexibility include the minimal atmospheric load (MEL) and ramp-up speeds, which are made possible by the air extraction and injection processes of the gas engine compressors, respectively.[15][16]Yu et.al. Presents the Brayton and Trans critical CO₂ refrigeration cycles that use CO₂ as the working fluid. Under design conditions, the energy and exergy efficiencies were discovered to be 42.42% and 39.05%, respectively, with an associated average energy cost of 9.28 \$/GJ. The low temperature recoup produced more work when the chatter cooler pressure was higher and the condensation temperature was lower. The refrigeration cycle is unaffected by the turbine temperature at the inlet, and the net work decreases as the inlet temperature rises. At the specified evaporation temperature range, the lowest energy efficiency of 42% is reached around 10⁰ C[16].

This article describes the classification of thermodynamic cycle. A general thermodynamic power cycle is composed of four fundamental processes, namely compression, heat addition at high pressure (p_2), expansion, and heat rejection at low pressure (p_1), and can be categorised according to whether phase change occurs within the cycle. Combining these definitions enables a general classification of thermodynamic cycles as reported in figure 1. The two sCO₂ cycles of primary interest are the supercritical cycle and the transcritical cycle, which are shown by the blue and green cycles in 1.




Figure 1 Classification of thermodynamic power cycles[17]

[17] Crespy et.al. Presents For two distinct engine inner heat (550°C and 700°C), CO₂-SO₂ mixtures were utilized as the function fluid in a recompression cycle. Results for two different cycle configurations are compared (Recuperated Rankin and Recompression). In comparison to the Brayton and repressing periods operating on pure form of CO₂, the suggested arrangement results in thermal efficiency increases of 6% and 2%, respectively. By using CO₂-SO₂, the Recompression cycle can achieve thermal efficiencies of more than 51% at a lesser cycle condition of 50 C[18].

[18] Fernandez et.al. Presents how various configurations of "Tran's critical carbon dioxide thermal energy storage system" cycles operate when high temperature solar heat is introduced, At a pressure gradient of 9.4 and without heliocal support, the base case's round trip efficiency is 52%. The efficiency is above 60% when solar input is taken into account, raising the turbine inlet temperature to 950 K[19].

[19] Shu et.al. Shows four unique CTRC configuration selection maps for waste heat recovery of engines. With the greatest turbine intake pressure (15 MPa) and greatest engine inner condition (740 °C), the best energy efficiency is 0.48. Systems with more heat exchangers produce higher net output power, but this does not imply that they are more cost-effective[20]. Another study gives a general, well-developed model that depicts the gas engine with turbine cooler, for medium and small machines, the present trend in the development of gas turbine technology is towards greater pressure ratios and turbine inlet temperatures, and primarily towards maximized turbine inlet temperatures for huge machines. Using the (DRIASI) dual-recuperated intercooled after cooled steam-injected cycle, gas turbine performance can be enhanced without having to raise the turbine's inlet temperature (from 1000 to 1400 °C) or pressure ratio (5 to 20 or 30)[21]. The most effective points were obtained at two different speeds (9172 and 9655 rpm) with $x_w=0.05$ and 0.1[22].

[22] Mansouri et.al. Presents the impact of three different kind of gas turbine merged power station with similar turbine as a quality cycle on combined cycle power plants' energy efficiency is assessed; the findings indicate that as the several levels for steam output increases, so do exergy destruction through heat exchange and stack gas exergy. Additionally, as steam is produced at higher pressure levels in HRSG, more heat is recovered from the flue gas, increasing the cycle's energy efficiency. Additionally, as the number of pressure levels for steam generation in HRSG increases, the cycle's exergy destruction rate lowers. It has been discovered that increasing the number of steam generation pressure levels causes an increase in the plant's overall and particular investment costs of roughly 6% and 4%, respectively. When compared to the double pressure CCGT, the triple pressure reheat boosts the plant's net present value (NPV) by around 7%[23].

[23] Mazur et.al. Presents, two 660 MW units both experienced last-stage turbine blade failures. The failures occurred in reduced pressure turbines linked to increased pressure turbines (LP1 and LP2) as well as LP turbines connected to generators (LP2). Torsional vibrations in the blades near 120 Hz and some operation times with low load and low vacuum were the main contributors to the failure[24]. [24] Low et.al. Presents employing steam turbine waste heat for vacuum desalination. The research presented here shows the practicality of the vacuum desalination system using waste turbine exhaust steam of low quality as a heating source. At a pressure of roughly 10 kPa, the temperature of a turbine's exhaust steam is high enough to bring sea water to a boil. The system's energy efficiency is significantly impacted by how well heat losses from the system can be reduced[25].

The exhaust temperature will climb to 700 C and the back pressure will rise to 0.032 MPa for the 50 MW condensing steam turbine unit that was the subject of this article. We can determine the impact on the unit owing to a change in back pressure by the computation of rated condition and variable condition[26].

4. Effect of Waste heat recovery/HRVG/Bottoming cycle pressure on cycle:

Trans critical CO₂ has advantages over conventional systems using other working fluids for low grade heat source recovery because it transfers heat more effectively than other pure working fluids. Annual optical efficiency, thermal efficiency, and overall efficiency for the planned plant are 52.1%, 38%, and 19.8%, respectively[27]. [31] Dai et.al. Presents Trans critical Rankin cycles because of security and environmental issues. Yet, the system's relatively poor efficiency must be raised, and the high operation pressure must be decreased. The findings showed that, in

comparison to pure CO₂, these zoetrope mixes can assist increase the thermal productivity of TRC and lower operating strain[28].

[32] Lee et.al. Presents a horizontal-tube falling-film ammonia-water absorber's heat and mass transport were studied. A solution's heat transfer coefficient was found to typically decrease with increasing pressure and diluted solution concentration for a constant solution flow rate. It was found that the damper temperature duty, overall heat transfer factor, and expanded heat transfer efficiency increased with increasing solution flow rate.[29].[33] Dzido et.al. Presents the most effective use of this technology was found when the CO₂ pressure was maximized. Liquid air energy storage technology and Tran's critical CO₂ cycle were combined to increase its efficiency. In a parallel system, efficiency levels are 5-6%, but in a subsequent cycle, they are only 3.5-5%. Due to the temperature cross in this system, heat from the compression part cannot be used to heat the air in the expansion section. Whereas in the parallel mode any pressure increase above 300 bars led to insignificant additional efficiency, pressure increases in the CO₂ cycle resulted to a gain in storage efficiency in each case[30].

[34] Sarmiento et.al. Presents the approach based on two parametric evaluations of the regenerator's heat transfer area and cost as well as the radial heat transfer in each solar collector at various operating pressures. Little fields of 20 solar HCE may tolerate high temperatures (315 °C) without compromising their energy efficiency because the area's thermal loss is reduced. The price maximizes the solar field's energy efficiency. Lower temperatures (120 °C) should be used in solar fields with 400 HCE, which have larger thermal losses. Due to its high working pressure, CO₂ has significant drawbacks[31].[37] Shu et.al. Presents, the utilization of CO₂ mixes in the Trans critical Rankin cycle to boost waste heat recovery capabilities in the engine. The best performance of CO₂/R32 (0.3/0.7) for the Trans critical Rankin cycle occurred at condensation temperatures less than 40 °C. CO₂/R161 (0.45/0.55) is an appropriate CO₂ mixture to use in all other circumstances. The ideal operating pressure for the CO₂/R161 (0.45/0.55) and CO₂/R32 (0.3/0.7) Trans critical Rankin cycles will be lower than that of the CO₂ Trans critical Rankin cycle by 36% and 35%, respectively. The optimal operating pressure is decreased by 1.4 MPa when comparing the CO₂/R32 Trans critical Rankin cycle to the CO₂ Trans critical Rankin cycle, while the net output power is improved by 8.8%. In contrast to CO₂/R32[32].

[38] Pan et.al gives an experimental investigation of the CO₂ Trans critical power cycle's operational parameters. There is a dramatic drop in the amount of electricity generated during the start-up mode. The electric power generated during operation increases with higher converter frequency and exhibits an inverse relationship with load resistance. Based on a scenario where the high pressure is around 11 MPa and the low pressure is approximately 4.6 MPa, the thermal efficiency of the generated electricity can exceed 1100 Wand. Around 21.4% of the isentropic efficiency[33].[39] Li et.al. Presents, According to the findings of a study between the impacts of mass flow rate and pressure ratio on dynamic responses among four CO₂ Trans critical power cycle (CTPC) systems, the basic CTPC system reacts around four times faster than the basic R123-ORC system[34]. [40] Yang et.al. The method that cycles CO₂ and fluoroethane performs economically best, surpassing systems that cycle CO₂ and difluoromethane, tetrafluoropropene, tetrafluoroethane, hydrogen, and pure CO₂ by factors of 0.7, 13.89, and 15. The Trans critical Rankin cycle, which uses carbon dioxide mixes together with high pressure and temperature, lowers energy costs[35].

5. Effect of Temperature on bottoming cycle:

When a revised trans critical CO₂ Rankin power cycle with reheat enhancement is compared to a baseline cycle without reheating relating to specific peak generation output output, it is discovered that regenerator increases thermal efficiency, though it does so more in the heat cycle because the latter's outlet temperature is higher [41]. This decreases the optimal reheat temperature, which maximizes thermal efficiency. The particular mesh production and thermal effectivity can be maximized at the same time using the regulator and reheater[36].[42]Hoque et al. present the impact of changes in room temperature on the weaker side intensity pressure, cycle effectivity, and peak result assessed in a thorough detemination of a 10 MW transcritical CO₂ Rankin cycle generation output CSP plant. The planned plant's annual optical, thermal, and overall efficiency is 52.1%, 38%, and 19.8%, respectively[27].

[43] AlZahrani et al. Outlines a hypothetical design for a reheat trans-critical carbon dioxide and observed that Energy and exergy efficiencies for the T-CO₂ power cycle were 34% and 82%, respectively. Energy and exergy efficiencies for integrated CSP (solar to electric) systems are roughly 20% and 55%, respectively.[37].[44] Xia et al. presented a comparison between various mixes and pure CO₂ was made. Transcritical CO₂ is prohibited when using organic fluids as lower-temperature cooling sources. A transcritical power sourcesutilizing CO₂-founded mixes might outperform a cycle using pure CO₂ in terms of thermodynamics and economic performance for both minimum and maximum-temperature warmth source adaptations[38].

[45] Zamfirescu et al. Demonstrates the ammonia-water Rankin cycle's operation. The efficiency of the process working with ammonia-water are 0.30 as opposed to the steam-only scenario, which exhibits an exergy efficiency of 0.23, resulting in an increase of 7.0% for the same operating circumstances. The cycle might be utilized for geothermal power, process heat rejection, low control, decreased heat restoration from solar sources, ocean internal energy transformation, etc[39].The optimal network, thermal efficiency, and exergy efficiency all increased compared to the conventional cycle by 4.87%, 3.62%, and 10.06%, respectively[40].[48] Mondal et al. present energy utilization from cold conditions heat recovering; CO₂ is possibility operative liquid because of its decreased crucial heat; the presence of optimal drain strains correlating to increased first low effectively or decreased period changeability for particular values of residual period limits; and the existence of optimal bleed pressures for CO₂[41].

[50] Hu et al. present the optimal circulation ratio for the liquid ammonia power on, which is according to the Kalina period of cycle, is 4, with a 12%–13% absorption variance in the ammonia-water solution. Also, increasing the NH₃-liquid solution concentration could enhance carrying out of the AWPC, although expanding the solution heat exchanger's terminal temperature difference would improve the power generation ratio[42].[51] Anand et al. provide a simulation that forecasts how an advanced industrial-scale ammonia-absorption system will function under a variety of practical operating circumstances. An ammonia-water absorption refrigeration system powered by low-temperature waste heat can provide subfreezing refrigeration for a variety of commercial uses notably food production, refrigeration, ice-making, paper and pulp manufacturing, and explosives[43].

[52] Chen et al. Under specific operating conditions, the presented water-ammonia absorption refrigeration system, whereas the cooler are operating below a significant heat rise and a less temperature energy when the GAX (Generator-Absorber heat exchange) impact is absent, an enhanced cycle is provided for the usage of rectification heat. Achieves a 24% higher in COP over the conventional exclusive-effect time period[44].[53] Mergner et al. contrasted using thermology computation on designs of current liquid ammonia periods, with the ammonia proportion of mass among 80% and 90% producing optimum execution for chosen supply of heat 393.15 K. NH₃/water-based cycles can boost the energetic efficiency by around 25% in contrast to an ORC utilizing R245fa as the heating medium[45].

[57] Padilla et al. give Rankine and absorption refrigeration cycles are coupled in a power/cooling cycle that simultaneously produces power and cooling utilizingan amalgamation of NH₃ and H₂O as the heat medium. At an absorber temperature of 30 °C, the greatest effective first law and exergy performances are premeditated to be 20% & 72%, accordingly. The temperature of cycle's heat source ranges from 90 to 170 °C[46].

[58] Chen et al. present An NH₃-liquid power cycle, including a purification level, indicating that the suggested process can generates 8% and 9% higher efficiency than mention Kalina cycles[47].[59] Romo et al. present the relationship between warmth and weight transfer in assimilation machines utilizing LiBr water and NH₃ liquid as working fluid pairs. As the assimilationrefrigerant circuit reaches evaporation temperatures under 0 °C, the heat and mass transfer coefficient is significantly increased[48].

[64] Meng et al. present a thermo-economic perspective; the benefits of Trans-critical CO₂ power cycles for cool-down heat resources are investigated. The Trans-critical CO₂ power cycle is adequate for cryogenic thermal sources when combined with ORC[49].[65] Liu et al. present utilizing both conventional and cutting-edge exergy analysis, a revolutionary two-phase transcritical condensed Co₂ power depot device. The most considerable exergy devastation value of 256.71 kW, accounting for 19.23% of entire exergy annihilation rate, designates freezer as the very critical element for enhancement. The system's energy efficiency is 59% for the actual cycle, while it is 77.8% at its highest possible level for the inevitable revolution[50].

[66] Ma.al. Presents a summary of refrigeration and heat pumps using transcritical carbon dioxide. The presentation of the CO₂ transcritical process can be raised to a level that is comparable to that a typical thermo compressor system by utilizing a domestic heat transfer, two-level contraction, function of growth restoration, and improved heat transfer[51]. [67] Wang et al. present that a substitute to traditional power generation, particularly for low-grade heat sources, is CO₂ power cycles. We explore the key designs and performance features of CO₂ generators[52].

[68] Sun et al. present Exergy research showing that both LNG and solar evenly supply exergy to CO₂ energy system in the heliocal transcritical CO₂ feeding cycle for hydrogen synthesis. Due to the significant temperature changes experienced throughout the heat transfer process, the solar collector and condenser experience tremendous energy losses. When the turbine inlet pressure and other factors are at their ideal levels, the system can produce 2.1 L/s of water and 11.52 kW of polar energy. Moreover, hydrogen generation has a potential energy efficiency of 12.38%[53]. [69] Sarmiento et al. presents the approach based on two parametric evaluations of rejuvenator heat transfer region & cost and the extremist heat exchange in every solar accumulator at various operating strains. Little fields of 20 solar HCE may tolerate high temperatures (315 °C) without compromising their energy effectivity because area's thermal loss is reduced. The price maximizes the solar field's energy efficiency. Lower temperatures (120 °C) should be used in solar fields with 400 HCE, which have more significant thermal losses. Due to its high working pressure, CO₂ has substantial drawbacks[31]. [70] Abdollahpour et al. An LNG and solar thermal subsystem are coupled with a transcritical CO₂ power cycle's thermodynamic & economic analysis. Under ideal conditions, the system may generate power at an annual cost of \$2.09 million and an energy efficiency of 8.53 percent. The condenser's costs are those of energy destruction since the exert-economic element has the lowest value, whereas the solar collectors' investment cost rate is the largest[54].

[55] presented the comparison of two cycles, the CO₂ trans critical power down cycle and the ORC utilizing various working fluids R601, R600a, R245fa and R123 shows that ORC performs better thermodynamically and is more successful at recovering low-grade heat. The developmental ORC utilizing R601 has the maximized thermal (14.05%) and energy efficiency, while the ORC using R123fa generates the most net power (192.7 KW). Economically, the CDTPC outperforms the ORC in terms of total output of power.

[56] Present the testing of Carbon-di-oxide and R125 Trans- critical cycles, and a substandard warmth source operating at roughly 100⁰C. The transcritical cycle with R125 generated 14% more electricity than the transcritical cycle with carbon dioxide. Nevertheless, the pressure drop and heat exchange capabilities of CO₂ cycle are superior heat exchangers. It is advised to use the Trans-critical cycle of R125 with inferior warm sources that are approximately 100⁰C. [57] present that in a dairy farm, transcritical CO₂ is utilized for refrigeration and water heating, making it evident that the thermal performance of CO₂ is better employed for heating than cooling.

[58] creation and suggestion of original, highly effective regeneration system according to the TRCC (transcritical CO₂) period for generating electricity, H₂, and aquatic using a combination of heliocal and geothermic sources of energy. The system produced the maximum power, hydrogen, and liquid, with 13.38 m³, 1.989 kg/h, and, 1286 kW/day accordingly. When operating at peak performance, the mechanism achieves a 23.35% power consumption with a 17.07/GJ unit cost. [59] investigate how high-temperature heat pump research discoveries can be used to advance non-consumable trans-critical heat turbine technology in the future to overcome significant technological challenges. Up to about 200 °C, new transcritical cycles can raise the COP to stages where they are reasonable with optional gases, run at manageable pressures, and generate mean temperature elevations of about 100 °C. [60] presents The overall net power and overall thermal efficiency of the regenerative CDTPC system are higher than those of the basic CDTPC system regardless of how the geothermal water mass flow rate and temperature or the cooling water temperature vary. These findings come from a study on the effects of a recuperate on the design and off-design performances of a CO₂ transcritical power cycle (CDTPC) for low-temperature geothermal plants.

[32] present to look into TRC performance enhancements for the WHR of the engine using CO₂ mixes. The CO₂ mixtures can expand the range of condensation temperatures for transcritical CO₂ combinations. When compared to the CTRC, the TRC with CO₂/R161 and CO₂/R32 will have an optimal operating pressure that is 36% and 35% lower, respectively. In comparison to the CTRC, the carbon dioxide TRC's whole power of output rises by 8.8%.

CO₂/R32 will result in a 29.4% reduction in the ideal entire heat exchange region growth when compared to CO₂-R32.[61] present that Using heat energy at low temperatures, the trans critical CO₂ power cycle's efficiency can be raised. The efficiency of four different trans critical CO₂ power cycles is evaluated. When compared to the organic Rankin and Rankin cycles, the trans critical process produces more net energy. The results show that of the four trans critical CO₂ cycles, the cycle with a reheating is chosen. The working liquid CO₂ is safer and more environmentally friendly than the ammonia-water mixture. To evaluate the thermodynamical and financial performance of the energy cycle, including a whole duration, a mathematical model is built. The region of the air-cooled capacitors are obtained using a spen EDR, and Mat lab calculates the complete thermo-economic performance.

[62] presents that 20% from the black dampened power may be converted into useable work in a CO₂ Trans critical power cycle with a gas heater that has a pressure of 130 bar and an increase in inlet with a temperature of 200°C. With an efficiency of roughly 19%, the process works continuously after the turning moment when strain in the gas refrigerator and the gas warmer increases. Additionally, the CO₂ blended cycle has a system COP of 2.32 and can convert 5% of the electrical energy it absorbs into emissions.

[63] an entirely renewable micro-hybrid energy function for producing heat and energy, is presented. ORC operation can handle much more thermic energy and significantly less electrical power (50.3% of the load) when the heat energy demand is given priority. The analysis shows that hybrid ORC systems ensure a biomass save of more than 21% compared to biomass-fired CHP units.

[64] Combining a Tran's essential CO₂ refrigeration system with a boosted-MED system to simultaneously deliver cooling and fresh water will keep 57% of power and 37.8% and 29.1% of overall yearly expenditures in Toronto and Tehran, correspondingly. [20] show there are four distinct CTRC configuration selection maps for engine waste heat recovery. The best energy efficiency is 0.48 with the largest turbine intake pressure (15 MPa) and largest turbine inlet temperature (740 OC). Higher net output power is produced by systems with more heat exchangers, but this does not necessarily mean that they are more cost-effective.[65] presents a carbon dioxide-based transcritical power cycle that gets its heat from a stream of industrial process gases of low quality. The outcome displayed that increasing the entire output from a finite power resource decreases energetic efficiency, improves the surface area of heat exchangers, and has no impact on the energy analysis's recommendations. Without a regenerator, the specific net power output is maximized at about 11.5 MPa, while the thermal and energy efficiency is at its peak around 13.5 MPa.

[66] A leap model turned out to be created forecast function execution under various operating situations. So, subsequent system and component design and optimization can be guided by the simulation results. Maximum system heat effectively could only be obtained when T-CO₂ Rankin cycle operates under specific circumstances, like elevated pressure at the turbine inner or less temperature source.

[67] In the reduced-temperature (i.e. 80-100 OC) geothermic power system, R123 in the subcritical ORC system produces the maximized heat effectivity and exergy productivity of 54.1% and 11.1% accordingly. This are due to parameter optimisation and execution matches the liquids in the super-critical ORC and transcritical energy cycles. Despite having a 20.7% greater recovery efficiency than R123's subcritical ORC, R125's transcritical cycle thermal efficiency and exergy efficiency are 46.4% and 20% less efficient than R123's respectively. The LEC value could also be very greater. Additionally, when the LEC value is utilized as the target cycle, 22032L of petroleum are saved in addition to a yearly reduction of 74,019 kg of CO₂. The use of R125 in the transcritical power cycle may maximise the utilisation of geothermal energy and has good economic and environmental performance.

[68] analysis of the off-design performance of a Trans critical CO₂ (tCO₂) power cycle utilising various operating methods; When the geothermal water inner temperature is raised, the best operation approach generates an increase of 1.19–1.98% above the net power at the design point. The radial turbine's first design had an efficiency of 83.1% with a rotational speed of 32000 rpm. The net power, thermal efficiency, and exergy efficiency for the complete tCO₂ power cycle are 272.02 kiloWatt, 8.20%, & 42.36%, accordingly. The basic tCO₂ power cycle's low exergy and high heat input from geothermal water, a low-grade heat source, result in a noticeable disparity in the thermal and exergy efficiency. [69] Three heating medium (CO₂, ethane, and R125) were compared with their optimal findings to show that good liquid relies on the amanded indication and a straightforward original law examinations is insufficient for working fluid assortment. For the source and sink under examination, the non-dimensional net power output value is close to 0.02. When the best indicators are compared between the three elements, neither of which exceeds two in every way. R125 has the highest warmth affectivity since ethane has most particular average output of power and the minimized entire heat transformation factor by exterior,UA, consistency, and cost.

Compared to ethane, the CO₂ has a lower heat exchange surface but a larger total UA. Compared to ethane, the CO₂ has a smaller heat exchange surface, but a larger total UA.

[70] present Transcritical power cycles (TPCs), which convert low-grade geothermal water at 100–150 °C into energy while cooling temperature of H₂O, are defined and explored. The study shows that R161/CO₂ offers the highest thermal and financial performance for TPC, but due to its poor thermal performance, R290/CO₂ could not be the ideal heating medium.[71] Offers energy and energetic evaluations, optimization studies, and a trans critical CO₂ thermo-compressor system. The COP tendencies show that the function is better suited to maximize warming end heats and low cool end heats.[72] present that the optimal heating COP of a transcritical CO₂ heating pump prototype was close to 3 when heating water to 90 °C, and it rose by around 10% when heating water to 65 °C or 77.5 °C. It was discovered that the compressor's isentropic efficiency remained relatively steady at approximately 70%, but at high-pressure ratios, the volumetric flow rate drastically decreased.[73] According to an optimization investigation of a trans critical CO₂ freezing cycle, analogous condensation curtailment is more effective at lower evaporator temperatures. For the examined ranges, parallel compression economization results in a maximum 47.3% increase in ideal COP.

[74] Expander efficiency in systems with no condensable gas is typically 25% greater when the inlet heat of the stretcher is 35 C, and the inner strains remains at 8 MPa. The affectivity of the extender increases when additional no condensable gas is added to system[32] present the improvements to the presentation the Trans critical Rankin cycle, which restores heat rejection from the engine using CO₂ composition. When the contraction temperature was less than 40 °C, CO₂/R32 worked effectively to produce the most power from the trans critical Rankin cycle. CO₂/R161 is a suitable CO₂ combination in all other situations. In comparison to the CO₂ transcritical Rankine cycle, the ideal operating pressure for the CO₂/R161 and CO₂/R32 transcritical Rankine cycles will be 36% and 35% lower, respectively. The net output power is 8.8% greater and the ideal operating pressure is 1.4 MPa lower when comparing the CO₂/R32 transcritical Rankine cycle to the CO₂/R2 transcritical Rankine cycle, respectively. The optimal CO₂/R32 total heat exchange zone increase will be 29.4% lower.

[75] Thermodynamic and financial comparisons between the novel single-pressure multi-stage CDTPCs and single-pressure single-stage CDTPC for engine waste heat recovery show that the double-stage CDTPC can generate the highest net power output of 517.27 kW for a 2928 kW engine at a temperature of exhaust gases of 470 0C. The one-stage CDTPC is the most economical choice when exhaust gas temperatures are between 300 and 600 0C, according to a professional economic research. For exhaust gas temperatures between 530 and 600 0C, the double-stage CDTPC is advised because to its improved thermodynamic and economic properties. When exhaust gas temperatures are between 300 and 600 0C, the three-stage CDTPC is not advised. [76] The CTPC system, which relies on CO₂ as its used fluid for generating electricity from less-ranked temperature resources, has better dynamic elements and an average transition of less time than 62 seconds.

[77] demonstrating how a thermoelectric sub-cooler and an ejector (TES+EJE) are now integrated with a trans critical CO₂ refrigeration cycle, The maximum Cop of the TES and EJE cycle is increased by 39.34% compared to the trans critical CO₂ refrigeration cycle under the predetermined operating conditions of 5 °C evaporation temperature and 40 °C gas cooler outlet temperature, and the equivalent optimal release pressure is minimized by 8.01%. [78] compare the most prevalent formations for transcritical individual-stage cycles utilizing CO₂ as the coolant and an energetic simulation of these setups. It is not be as good to employ an inner heat transformation when the evaporative cooler outer heat is less than 31 C. It is not recommended to use an internal heat exchanger in a configuration in a Trans critical cycle employing a turbine as an expander device at gas refrigerator outer temperatures lower 40 C.[79] Currently, the system uses a heliacal-energized trans- critical CO₂ cycle of power and cold waste heat to an LNG vaporization conditions. The system's ability to create electricity well after sunset is made possible by the thermal storage tank, even though the total output power generation predominantly relies on solar power for one day. Efficiency can reach about 6.51% when utilizing LNG as the heat dissipation for the whole energy cycle. system's performance is highly influenced by the condensation temperature; as the turbine input temperature drops, the system's efficiency noticeably rises.

6. Effect of Waste heat recovery/HRVG/Bottoming cycle pressure on cycle:

Thorough inquiry of unusual heat rejection restoration power cycles was done by [80], and it was discovered that the Kalina bottoming cycle is more competing to restore sub-standard heat rejection than the natural Rankine cycle

when in contrast to traditional penetrating cycles, like the engine Rankine cycle.[81] demonstrates investigations of power down cycle using NH₃-liquid compositions as the heating medium and various types of temperature resources to generate heat and power, showing that these cycles are ideally adapted for using waste heat from petrol engines and from industries. In comparison to a traditional Rankine steam cycle, the NH₃-water power down could provide up 32% more consumption in the toxic heat rejection utilization and up to 54% more energy in the gas turbine penetrating cycle uses.[82] Presents A combination cooling, desalination, and power (CCDP) system based on NH₃ and H₂O is presented. It consists of an ocean thermal energy conversion (OTEC) unit that uses the Kalina cycle, an ejector refrigeration cycle, and a spray flash evaporation (SFE) desalination unit. The three parts—the SFE, condenser, and turbine—account for more than 70% of all energy destruction. By lowering the condensation pressure and increasing the basic ammonia concentration, both effective efficiency and exergy efficiency can be increased.[83] presents The simple gas turbine with bottoming cycle, the reheat ammonia water turbine, and the steam turbine are found to produce the most work at a rate of 638 kJ/kg of air with first and second law efficiency values of 57.87% and 54.95%, respectively, in thermodynamic analysis of various combined cycle power plants.

[84] A new ammonia-based combined heating and power (CHP) system is reported that combines an overheated Kalina cycle with a compressing heat pump cycle to deliver power and hot air to clients concurrently. The system with the highest energy efficiency is one with high pressure. There is an increased pressure operation that function well and has the most energy efficiency. Lower system middle pressure and partition temperature, greater system reduced pressure and NH₃ bulk percentage would result in higher system energy efficiency within specified ranges. The function of energy productivity is only marginally impacted by turbine's input temperature.[75] examines the differences in thermodynamics and exergoeconomics among the unique-pressure, individual-level CDTPC for turbine heat rejection revival and the ground-breaking single-pressure, multi-stage CDTPCs.

[85] Explains novel thermoelectric (TE) sub cooler and expander combinations with transcritical CO₂ refrigeration cycles. The newly proposed TES+EXPML cycle outperforms conventional cycles with outstanding and consistent performance. It operates with both the lowest discharge pressure and the maximum COP.[86] Radial turbine expanding devices with traditional carbon ring sealing mechanisms and angular contact ceramic ball bearings are now created expressly for an experimental CTPC system, an engine waste heat reclamation device. Experiments using turbine expanders are carried out on the CTPC experimental bench. The turbine rotates between 10,554 and 14,684 rpm depending on the resistance load, reaching its maximum power production of 692W at 14,022 rpm.. At 13,366 rpm, maximum efficiency of 53.43% is reached before speeding down. The leakage brought on by the dynamic seal's failure is the cause of the turbine expander's low power output.[107] [87] Presents a progressive system that combines assimilation refrigeration (AR) with the TCPC for inferior heat recovery is subjected to power, economic, and atmospheric determination. The final ideal solution results in a gain in thermal efficiency of 13.17% and a decrease in Eco-indicator 16 of 13.49% at the expense of increased in whole cost of 8.94%.The authors belonging to [87] Shows a molecule transformation lamina electrochemical cell to revival wastage of heat generated in blended system comprised of transcritical CO₂ periods and a watery organic evaporated cycle. hybrid system's power consumption by 39% when contrast to standalone systems, and its efficiency increased to 72% after optimization, from 39% before the heat restoration function was used. It could also convert LNG into natural gas and deliver some chilled water.Similarly [88] Presents the CTPC applications behave slowly to changes in engine conditions, such as turbine speed and expanding valve opening, but they have the capacity to generate power and run continuously and safely for a limited number of times. The systems conduct as a second-order under muffled operation when these conditions change. On a built-in test bench, CO₂ trans critical power cycle (CTPC) devices are energetically evaluated using valve for expanding. The CTPC systems exhibit considerable potential for recovering waste heat from truck engines since they are resilient to narrow variations of heat sources and quick to make adjustments when necessary.[56] Presents the evaluation of R125 and CO₂ transcritical cycles for an inferior heat resource operating at roughly 100 °C. Despite the fact that the R125 transcritical cycle generated 14% more power, the fall in pressure and heat transfer properties of the carbon dioxide cycle were superior in heat exchangers. Low grading sources of heating with temperatures of up to 100 0C are advised to use the R125 trans critical circuit.

The following table provides comparative analysis in correlation with the present study

Table 1: Energy and exergy analysis of the existing articles – A comparative table

References	Year	Energy analysis	Capacity (MW)		Exergy analysis	Results
(Ahmadi & Toghraie, 2016)	2016	yes	200		yes	The boiler was a primary energy-wasting element whereas its condenser was the foremost energy-wasting component.
(Suresh, Reddy, & Kolar, 2011)	2017	yes	660		yes	The most effective characteristics for the power plant's thermal optimization have been discovered utilizing a combined artificial neural network (ANN) technique and a genetic algorithm (GA).
(Abuelnuor et al., 2017)	2017	--	180		yes	The primary sources of exergy degradation are combustion environments because of their extreme irreversible nature.
(Ibrahim et al., 2017)	2017	yes	250		yes	According to the findings, the plant's conserving energy were 34.3% while its vitality performance was 32.4%.
(Adibhatla & Kaushik, 2017)	2017	yes	430.54		yes	The absorbed steam generating CCPP is evaluated using energy consumption and exertion analysis.
(Manesh & Rosen, 2018)	2018	--	315		yes	For many different scenarios, the simulated structure can accurately estimate the breakdown of energy in the process with a proportional error of less than one percent.
(Parikhani, Ghaebi, & Rostamzadeh, 2018)	2018	yes	2.33		yes	The production system is suggested to have energy and exergy measurements.
(Sadreddini, Fani, Aghdam, & Mohammadi, 2018)	2018	--	0.033		yes	Fifty percent of the plants' total energy destruction occurred in the internal combustion zone.

The following figure 2 deliberates the distribution analysis of the incorporated articles




Figure 2 : Distribution analysis of the presetned articles

7. Conclusion:

In this report, recent advancements in modified transcritical CO₂ refrigeration cycle and ammonia water as refrigerant in technology over the previous 25 years are compiled. Several technologies have been shown to have promise for raising operating pressure and improving energy efficiency. In light of the many uses, it is predicted that this study will help determine the optimal technique for CO₂ transcritical refrigeration. The key conclusions and future predictions are as follows:

- A compression heat pump cycle is seen in the bottom cycle, is used to recover a significant quantity of energy that was left in the NH₃-weak fluid that was worn out from the extractor of the Kalina cycle.
- Main disadvantage of the expander, sub cooling, flash gas bypass, and two-stage compression is the complexity of their systems; as a result, the final decision is made by finding the best balance between higher installation costs and lower operating costs, while also taking into account the system's reliability and safety features.
- Trans-critical CO₂ heat pumps function well in applications for heating water and air. Modifications like dual-stage compression, multi-stage expansion, expansion work recovery, and heat exchanger optimization can improve the performance of the fundamental Trans critical cycle.
- Tran's critical CO₂ cycles can function effectively for some commercial refrigeration applications, heat pump water heaters, and vehicle air conditioning.

References

- [1] H. K. Kayadelen, Y. Ust, and V. Bashan, "Thermodynamic performance analysis of state of the art gas turbine cycles with inter-stage turbine reheat and steam injection," *Energy*, vol. 222, p. 119981, 2021.
- [2] M. K. Sahu, "Comparative exergoeconomic analysis of basic and reheat gas turbine with air film blade cooling," *Energy*, vol. 132, pp. 160-170, 2017.
- [3] M. Maheshwari and O. Singh, "Thermo-economic analysis of combined cycle configurations with intercooling and reheating," *Energy*, vol. 205, p. 118049, 2020.
- [4] A. Khaliq and S. Kaushik, "Thermodynamic performance evaluation of combustion gas turbine cogeneration system with reheat," *Applied thermal engineering*, vol. 24, pp. 1785-1795, 2004.
- [5] G. Ma, Y. Zhang, M. Yue, and Y. Shi, "Thermal economy study on the waste heat utilization of a double reheat unit under coupled steam turbine and boiler," *Applied Thermal Engineering*, vol. 175, p. 115112, 2020.
- [6] I. Opreş and V.-E. Cenuşă, "Parametric and heuristic optimization of multiple schemes with double-reheat ultra-supercritical steam power plants," *Energy*, vol. 266, p. 126454, 2023.
- [7] S. Zhang, M. Liu, Y. Ma, J. Liu, and J. Yan, "Flexibility assessment of a modified double-reheat Rankine cycle integrating a regenerative turbine during recuperative heater shutdown processes," *Energy*, vol. 233, p. 121068, 2021.
- [8] M. Rashidi, O. A. Bég, A. B. Parsa, and F. Nazari, "Analysis and optimization of a transcritical power cycle with regenerator using artificial neural networks and genetic algorithms," *Proceedings of the Institution of Mechanical Engineers, Part A: Journal of Power and Energy*, vol. 225, pp. 701-717, 2011.
- [9] R. Khan, A. K. Shukla, M. Sharma, R. K. Phanden, and S. Mishra, "Thermodynamic investigation of intercooled reheat gas turbine combined cycle with carbon capture and methanation," *Materials Today: Proceedings*, vol. 38, pp. 449-455, 2021.
- [10] V. B. Hemadri and P. Subbarao, "Thermal integration of reheated organic Rankine cycle (RH-ORC) with gas turbine exhaust for maximum power recovery," *Thermal Science and Engineering Progress*, vol. 23, p. 100876, 2021.
- [11] S. S. Bishal, D. F. Faysal, M. M. Ehsan, and S. Salehin, "Performance evaluation of an integrated cooling and power system combining supercritical CO₂, gas turbine, absorption refrigeration, and organic rankine cycles for waste energy recuperating system," *Results in Engineering*, vol. 17, p. 100943, 2023.
- [12] J. Nondy and T. K. Gogoi, "Comparative performance analysis of four different combined power and cooling systems integrated with a topping gas turbine plant," *Energy Conversion and Management*, vol. 223, p. 113242, 2020.
- [13] Y. Li, Y. Lin, Y. He, G. Zhang, L. Zhang, J. Yang, *et al.*, "Part-load performance analysis of a dual-recuperated gas turbine combined cycle system," *Energy*, vol. 269, p. 126744, 2023.
- [14] M. Maheshwari and O. Singh, "Thermodynamic study of different configurations of gas-steam combined cycles employing intercooling and different means of cooling in topping cycle," *Applied Thermal Engineering*, vol. 162, p. 114249, 2019.
- [15] K. Abudu, U. Igie, I. Roumeliotis, and R. Hamilton, "Impact of gas turbine flexibility improvements on combined cycle gas turbine performance," *Applied Thermal Engineering*, vol. 189, p. 116703, 2021.
- [16] A. Yu, W. Su, X. Lin, N. Zhou, and L. Zhao, "Thermodynamic analysis on the combination of supercritical carbon dioxide power cycle and transcritical carbon dioxide refrigeration cycle for

- the waste heat recovery of shipboard," *Energy Conversion and Management*, vol. 221, p. 113214, 2020.
- [17] M. T. White, G. Bianchi, L. Chai, S. A. Tassou, and A. I. Sayma, "Review of supercritical CO₂ technologies and systems for power generation," *Applied Thermal Engineering*, vol. 185, p. 116447, 2021.
- [18] F. Crespi, P. R. de Arriba, D. Sánchez, and A. Muñoz, "Preliminary investigation on the adoption of CO₂-SO₂ working mixtures in a transcritical Recompression cycle," *Applied Thermal Engineering*, vol. 211, p. 118384, 2022.
- [19] R. Fernandez, R. Chacartegui, A. Becerra, B. Calderon, and M. Carvalho, "Transcritical carbon dioxide charge-discharge energy storage with integration of solar energy," *Journal of Sustainable Development of Energy, Water and Environment Systems*, vol. 7, pp. 444-465, 2019.
- [20] G. Shu, L. Shi, H. Tian, S. Deng, X. Li, and L. Chang, "Configurations selection maps of CO₂-based transcritical Rankine cycle (CTRC) for thermal energy management of engine waste heat," *Applied Energy*, vol. 186, pp. 423-435, 2017.
- [21] O. Bolland and J. Stadaas, "Comparative evaluation of combined cycles and gas turbine systems with water injection, steam injection, and recuperation," 1995.
- [22] S. Camporeale and B. Fortunato, "Performance of a mixed gas-steam cycle power plant obtained upgrading an aero-derivative gas turbine," *Energy conversion and management*, vol. 39, pp. 1683-1692, 1998.
- [23] M. T. Mansouri, P. Ahmadi, A. G. Kaviri, and M. N. M. Jaafar, "Exergetic and economic evaluation of the effect of HRSG configurations on the performance of combined cycle power plants," *Energy Conversion and Management*, vol. 58, pp. 47-58, 2012.
- [24] Z. Mazur, R. Garcí a-Illescas, and A. Herna´ ndez-Rossette, "Steam turbine low pressure blades fatigue failures caused by operational and external conditions," in *Turbo Expo: Power for Land, Sea, and Air*, 2009, pp. 93-106.
- [25] S. Low and J. Tay, "Vacuum desalination using waste heat from a steam turbine," *Desalination*, vol. 81, pp. 321-331, 1991.
- [26] S. Tu, Q. Zhou, J. L. Jian, C. Q. Ding, and S. M. Wu, "Application Study on Low Vacuum Circulating Water Heat Supply of a 50 MW Turbine," in *Advanced Materials Research*, 2014, pp. 896-899.
- [27] S. J. Hoque, P. Kumar, and P. Dutta, "Concentrating Solar Powered Transcritical CO₂ Power Generation Cycle for the Union Territory of Ladakh, India," *International Journal of Energy for a Clean Environment*, vol. 24, 2023.
- [28] B. Dai, M. Li, and Y. Ma, "Thermodynamic analysis of carbon dioxide blends with low GWP (global warming potential) working fluids-based transcritical Rankine cycles for low-grade heat energy recovery," *Energy*, vol. 64, pp. 942-952, 2014.
- [29] S. Lee, L. K. Bohra, S. Garimella, and A. K. Nagavarapu, "Measurement of absorption rates in horizontal-tube falling-film ammonia-water absorbers," *International journal of refrigeration*, vol. 35, pp. 613-632, 2012.
- [30] A. Dzido, M. Wołowicz, and P. Krawczyk, "Transcritical carbon dioxide cycle as a way to improve the efficiency of a Liquid Air Energy Storage system," *Renewable Energy*, vol. 196, pp. 1385-1391, 2022.
- [31] C. Sarmiento, J. M. Cardemil, A. J. Díaz, and R. Barraza, "Parametrized analysis of a carbon dioxide transcritical Rankine cycle driven by solar energy," *Applied Thermal Engineering*, vol. 140, pp. 580-592, 2018.
- [32] G. Shu, Z. Yu, H. Tian, P. Liu, and Z. Xu, "Potential of the transcritical Rankine cycle using CO₂-based binary zeotropic mixtures for engine's waste heat recovery," *Energy Conversion and Management*, vol. 174, pp. 668-685, 2018.

- [33] L. Pan, B. Li, X. Wei, and T. Li, "Experimental investigation on the CO₂ transcritical power cycle," *Energy*, vol. 95, pp. 247-254, 2016.
- [34] X. Li, G. Shu, H. Tian, G. Huang, P. Liu, X. Wang, *et al.*, "Experimental comparison of dynamic responses of CO₂ transcritical power cycle systems used for engine waste heat recovery," *Energy Conversion and Management*, vol. 161, pp. 254-265, 2018.
- [35] M.-H. Yang, "The performance analysis of the transcritical Rankine cycle using carbon dioxide mixtures as the working fluids for waste heat recovery," *Energy Conversion and Management*, vol. 151, pp. 86-97, 2017.
- [36] H. Tuo, "Thermal-economic analysis of a transcritical Rankine power cycle with reheat enhancement for a low-grade heat source," *International Journal of Energy Research*, vol. 37, pp. 857-867, 2013.
- [37] A. A. AlZahrani and I. Dincer, "Thermodynamic analysis of an integrated transcritical carbon dioxide power cycle for concentrated solar power systems," *Solar Energy*, vol. 170, pp. 557-567, 2018.
- [38] J. Xia, J. Wang, G. Zhang, J. Lou, P. Zhao, and Y. Dai, "Thermo-economic analysis and comparative study of transcritical power cycles using CO₂-based mixtures as working fluids," *Applied Thermal Engineering*, vol. 144, pp. 31-44, 2018.
- [39] C. Zamfirescu and I. Dincer, "Thermodynamic analysis of a novel ammonia–water trilateral Rankine cycle," *Thermochimica acta*, vol. 477, pp. 7-15, 2008.
- [40] Z. Wang, S. Du, L. Wang, and X. Chen, "Parameter analysis of an ammonia-water power cycle with a gravity assisted thermal driven "pump" for low-grade heat recovery," *Renewable Energy*, vol. 146, pp. 651-661, 2020.
- [41] S. Mondal and S. De, "Transcritical CO₂ power cycle—effects of regenerative heating using turbine bleed gas at intermediate pressure," *Energy*, vol. 87, pp. 95-103, 2015.
- [42] B. Hu, S. Huang, Y. Shao, and J. Chen, "Thermodynamic analysis of a new ammonia-water power cycle," *Energy Reports*, vol. 6, pp. 567-573, 2020.
- [43] G. Anand, D. C. Erickson, and E. Makar, "Characterization of Ammonia–Water Absorption Chiller and Application," *International Journal of Air-Conditioning and Refrigeration*, vol. 26, p. 1850035, 2018.
- [44] X. Chen, R. Wang, and S. Du, "An improved cycle for large temperature lifts application in water-ammonia absorption system," *Energy*, vol. 118, pp. 1361-1369, 2017.
- [45] H. Mergner and T. Weimer, "Performance of ammonia–water based cycles for power generation from low enthalpy heat sources," *Energy*, vol. 88, pp. 93-100, 2015.
- [46] R. V. Padilla, G. Demirkaya, D. Y. Goswami, E. Stefanakos, and M. M. Rahman, "Analysis of power and cooling cogeneration using ammonia-water mixture," *Energy*, vol. 35, pp. 4649-4657, 2010.
- [47] X. Chen, R. Wang, L. Wang, and S. Du, "A modified ammonia-water power cycle using a distillation stage for more efficient power generation," *Energy*, vol. 138, pp. 1-11, 2017.
- [48] B. Narváez-Romo, M. Chhay, E. W. Zavaleta-Aguilar, and J. R. Simões-Moreira, "A critical review of heat and mass transfer correlations for LiBr-H₂O and NH₃-H₂O absorption refrigeration machines using falling liquid film technology," *Applied thermal engineering*, vol. 123, pp. 1079-1095, 2017.
- [49] F. Meng, E. Wang, B. Zhang, F. Zhang, and C. Zhao, "Thermo-economic analysis of transcritical CO₂ power cycle and comparison with Kalina cycle and ORC for a low-temperature heat source," *Energy Conversion and Management*, vol. 195, pp. 1295-1308, 2019.
- [50] Z. Liu, B. Liu, J. Guo, X. Xin, and X. Yang, "Conventional and advanced exergy analysis of a novel transcritical compressed carbon dioxide energy storage system," *Energy conversion and management*, vol. 198, p. 111807, 2019.

- [51] Y. Ma, Z. Liu, and H. Tian, "A review of transcritical carbon dioxide heat pump and refrigeration cycles," *Energy*, vol. 55, pp. 156-172, 2013.
- [52] E. Wang, N. Peng, and M. Zhang, "System design and application of supercritical and transcritical CO₂ power cycles: A review," *Frontiers in Energy Research*, vol. 9, p. 723875, 2021.
- [53] Z. Sun, J. Wang, Y. Dai, and J. Wang, "Exergy analysis and optimization of a hydrogen production process by a solar-liquefied natural gas hybrid driven transcritical CO₂ power cycle," *International Journal of Hydrogen Energy*, vol. 37, pp. 18731-18739, 2012.
- [54] A. Abdollahpour, R. Ghasempour, A. Kasaeian, and M. H. Ahmadi, "Exergoeconomic analysis and optimization of a transcritical CO₂ power cycle driven by solar energy based on nanofluid with liquefied natural gas as its heat sink," *Journal of Thermal Analysis and Calorimetry*, vol. 139, pp. 451-473, 2020.
- [55] M. Li, J. Wang, S. Li, X. Wang, W. He, and Y. Dai, "Thermo-economic analysis and comparison of a CO₂ transcritical power cycle and an organic Rankine cycle," *Geothermics*, vol. 50, pp. 101-111, 2014.
- [56] Y.-J. Baik, M. Kim, K. C. Chang, and S. J. Kim, "Power-based performance comparison between carbon dioxide and R125 transcritical cycles for a low-grade heat source," *Applied Energy*, vol. 88, pp. 892-898, 2011.
- [57] J. Wang, M. Belusko, H. Semsarilar, M. Evans, M. Liu, and F. Bruno, "An optimisation study on a real-world transcritical CO₂ heat pump system with a flash gas bypass," *Energy Conversion and Management*, vol. 251, p. 114995, 2022.
- [58] H. Li, Y. Tao, Y. Zhang, and H. Fu, "Two-objective optimization of a hybrid solar-geothermal system with thermal energy storage for power, hydrogen and freshwater production based on transcritical CO₂ cycle," *Renewable Energy*, vol. 183, pp. 51-66, 2022.
- [59] K.-M. Adamson, T. G. Walmsley, J. K. Carson, Q. Chen, F. Schlosser, L. Kong, *et al.*, "High-temperature and transcritical heat pump cycles and advancements: A review," *Renewable and Sustainable Energy Reviews*, vol. 167, p. 112798, 2022.
- [60] C. Wu, S.-s. Wang, and J. Li, "Parametric study on the effects of a recuperator on the design and off-design performances for a CO₂ transcritical power cycle for low temperature geothermal plants," *Applied Thermal Engineering*, vol. 137, pp. 644-658, 2018.
- [61] J. Meng, M. Wei, P. Song, R. Tian, L. Hao, and S. Zheng, "Performance evaluation of a solar transcritical carbon dioxide Rankine cycle integrated with compressed air energy storage," *Energy Conversion and Management*, vol. 215, p. 112931, 2020.
- [62] C. Yang, "Thermodynamic cycles using carbon dioxide as working fluid: CO₂ transcritical power cycle study," KTH Royal Institute of Technology (KTH), 2011.
- [63] P. Morrone, A. Algieri, and T. Castiglione, "Hybridisation of biomass and concentrated solar power systems in transcritical organic Rankine cycles: A micro combined heat and power application," *Energy conversion and management*, vol. 180, pp. 757-768, 2019.
- [64] A. Farsi, S. H. Mohammadi, and M. Ameri, "An efficient combination of transcritical CO₂ refrigeration and multi-effect desalination: energy and economic analysis," *Energy Conversion and Management*, vol. 127, pp. 561-575, 2016.
- [65] E. Cayer, N. Galanis, M. Desilets, H. Nesreddine, and P. Roy, "Analysis of a carbon dioxide transcritical power cycle using a low temperature source," *Applied Energy*, vol. 86, pp. 1055-1063, 2009.
- [66] Y. Ge, L. Li, X. Luo, and S. Tassou, "Performance evaluation of a low-grade power generation system with CO₂ transcritical power cycles," *Applied energy*, vol. 227, pp. 220-230, 2018.
- [67] Z. Shengjun, W. Huaixin, and G. Tao, "Performance comparison and parametric optimization of subcritical Organic Rankine Cycle (ORC) and transcritical power cycle system for low-temperature geothermal power generation," *Applied energy*, vol. 88, pp. 2740-2754, 2011.

- [68] Y. Du, H. Chen, M. Hao, X. Qiang, J. Wang, and Y. Dai, "Off-design performance comparative analysis of a transcritical CO₂ power cycle using a radial turbine by different operation methods," *Energy Conversion and Management*, vol. 168, pp. 529-544, 2018.
- [69] E. Cayer, N. Galanis, and H. Nesreddine, "Parametric study and optimization of a transcritical power cycle using a low temperature source," *Applied Energy*, vol. 87, pp. 1349-1357, 2010.
- [70] C. Wu, S.-s. Wang, X. Jiang, and J. Li, "Thermodynamic analysis and performance optimization of transcritical power cycles using CO₂-based binary zeotropic mixtures as working fluids for geothermal power plants," *Applied Thermal Engineering*, vol. 115, pp. 292-304, 2017.
- [71] J. Sarkar, S. Bhattacharyya, and M. R. Gopal, "Optimization of a transcritical CO₂ heat pump cycle for simultaneous cooling and heating applications," *International Journal of Refrigeration*, vol. 27, pp. 830-838, 2004.
- [72] S. White, M. Yarrall, D. Cleland, and R. Hedley, "Modelling the performance of a transcritical CO₂ heat pump for high temperature heating," *International Journal of Refrigeration*, vol. 25, pp. 479-486, 2002.
- [73] J. Sarkar and N. Agrawal, "Performance optimization of transcritical CO₂ cycle with parallel compression economization," *International Journal of Thermal Sciences*, vol. 49, pp. 838-843, 2010.
- [74] T. Hua, M. Yitai, L. Minxia, G. Haiqing, and L. Zhongyan, "Influence of a non-condensable gas on the performance of a piston expander for use in carbon dioxide trans-critical heat pumps," *Applied thermal engineering*, vol. 31, pp. 1943-1949, 2011.
- [75] S.-s. Wang, C. Wu, and J. Li, "Exergoeconomic analysis and optimization of single-pressure single-stage and multi-stage CO₂ transcritical power cycles for engine waste heat recovery: A comparative study," *Energy*, vol. 142, pp. 559-577, 2018.
- [76] X. Li, G. Shu, H. Tian, L. Shi, G. Huang, T. Chen, *et al.*, "Preliminary tests on dynamic characteristics of a CO₂ transcritical power cycle using an expansion valve in engine waste heat recovery," *Energy*, vol. 140, pp. 696-707, 2017.
- [77] X. Liu, R. Fu, Z. Wang, L. Lin, Z. Sun, and X. Li, "Thermodynamic analysis of transcritical CO₂ refrigeration cycle integrated with thermoelectric subcooler and ejector," *Energy Conversion and Management*, vol. 188, pp. 354-365, 2019.
- [78] V. Pérez-García, J. Belman-Flores, J. Navarro-Esbrí, and C. Rubio-Maya, "Comparative study of transcritical vapor compression configurations using CO₂ as refrigeration mode base on simulation," *Applied Thermal Engineering*, vol. 51, pp. 1038-1046, 2013.
- [79] Y. Song, J. Wang, Y. Dai, and E. Zhou, "Thermodynamic analysis of a transcritical CO₂ power cycle driven by solar energy with liquified natural gas as its heat sink," *Applied energy*, vol. 92, pp. 194-203, 2012.
- [80] M. Saghafifar, A. Omar, K. Mohammadi, A. Alashkar, and M. Gadalla, "A review of unconventional bottoming cycles for waste heat recovery: Part I—Analysis, design, and optimization," *Energy Conversion and Management*, vol. 198, p. 110905, 2019.
- [81] E. Thorin, "Power cycles with ammonia-water mixtures as working fluid," *Kemiteknik*, 2000.
- [82] S. Zhou, X. Liu, K. Zhang, Q. Yue, Y. Bian, and S. Shen, "Evaluation of a novel ammonia-water based combined cooling, desalination and power system based on thermodynamic and exergoeconomic analyses," *Energy conversion and Management*, vol. 239, p. 114176, 2021.
- [83] M. Maheshwari and O. Singh, "Comparative evaluation of different combined cycle configurations having simple gas turbine, steam turbine and ammonia water turbine," *Energy*, vol. 168, pp. 1217-1236, 2019.
- [84] J. Wang, J. Wang, P. Zhao, and Y. Dai, "Proposal and thermodynamic assessment of a new ammonia-water based combined heating and power (CHP) system," *Energy conversion and management*, vol. 184, pp. 277-289, 2019.

- [85] B. Dai, S. Liu, K. Zhu, Z. Sun, and Y. Ma, "Thermodynamic performance evaluation of transcritical carbon dioxide refrigeration cycle integrated with thermoelectric subcooler and expander," *Energy*, vol. 122, pp. 787-800, 2017.
- [86] G. Huang, G. Shu, H. Tian, L. Shi, W. Zhuge, and L. Tao, "Experiments on a small-scale axial turbine expander used in CO₂ transcritical power cycle," *Applied Energy*, vol. 255, p. 113853, 2019.
- [87] P. Yang, M. Yuan, Z. Liu, N. Xie, Y. Liu, and S. Yang, "Multi-objective optimization and life cycle assessment of a cascade system integrating LiBr/H₂O absorption refrigeration with transcritical CO₂ power cycle," *Energy Conversion and Management*, vol. 244, p. 114453, 2021.
- [88] M. H. Ahmadi, A. Mohammadi, F. Pourfayaz, M. Mehrpooya, M. Bidi, A. Valero, *et al.*, "Thermodynamic analysis and optimization of a waste heat recovery system for proton exchange membrane fuel cell using transcritical carbon dioxide cycle and cold energy of liquefied natural gas," *Journal of Natural Gas Science and Engineering*, vol. 34, pp. 428-438, 2016.